

# Detailed Test Report

JobID : **1221542** Company : **KING OF THE CASTLES**  
Engineer : **David Lawton**

Test Date : **14/07/26**  
Total Tests : **70**

Location :

Room :

|                         |                                                             |                          |                            |                                                            |                       |
|-------------------------|-------------------------------------------------------------|--------------------------|----------------------------|------------------------------------------------------------|-----------------------|
| Asset ID<br><b>1056</b> | Description : <b>Splitter</b><br>Visual : <b>PASS</b>       | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1057</b> | Description : <b>Splitter</b><br>Visual : <b>PASS</b>       | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1058</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1059</b> | Description : <b>Extension Reel</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1060</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1061</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1062</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1063</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1064</b> | Description : <b>Power Lead</b><br>Visual : <b>PASS</b>     | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1065</b> | Description : <b>Power Lead</b><br>Visual : <b>PASS</b>     | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1066</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1067</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1068</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1069</b> | Description : <b>Extension Reel</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1070</b> | Description : <b>Extension Reel</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1071</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1072</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1073</b> | Description : <b>Extension Reel</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1074</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>      | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |

# Detailed Test Report

JobID : **1221542** Company : **KING OF THE CASTLES**  
Engineer : **David Lawton**

Test Date : **14/07/26**  
Total Tests : **70**

|                         |                                                         |                          |                            |                                                            |                       |
|-------------------------|---------------------------------------------------------|--------------------------|----------------------------|------------------------------------------------------------|-----------------------|
| Asset ID<br><b>1075</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1076</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1077</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1078</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1079</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1080</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1081</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1082</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1083</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1084</b> | Description : <b>Splitter</b><br>Visual : <b>PASS</b>   | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1085</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1086</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1087</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1088</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1089</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1090</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1091</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1092</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1093</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1094</b> | Description : <b>Air blower</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |

# Detailed Test Report

JobID : **1221542** Company : **KING OF THE CASTLES**  
Engineer : **David Lawton**

Test Date : **14/07/26**  
Total Tests : **70**

|                         |                                       |                      |                          |                            |                                                            |                       |
|-------------------------|---------------------------------------|----------------------|--------------------------|----------------------------|------------------------------------------------------------|-----------------------|
| Asset ID<br><b>1095</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1096</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1097</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1098</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1099</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1100</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1101</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 1 B</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1102</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1103</b> | Description :<br>Visual : <b>PASS</b> | Air blower           | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1104</b> | Description :<br>Visual : <b>PASS</b> | Extension            | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1105</b> | Description :<br>Visual : <b>PASS</b> | Extension            | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1106</b> | Description :<br>Visual : <b>PASS</b> | Extension            | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1107</b> | Description :<br>Visual : <b>PASS</b> | Extension            | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1108</b> | Description :<br>Visual : <b>PASS</b> | Extension            | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1109</b> | Description :<br>Visual : <b>PASS</b> | Extension            | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>          | Result<br><b>PASS</b> |
| Asset ID<br><b>1110</b> | Description :<br>Visual : <b>PASS</b> | Generator power lead | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>415B</b><br>Sub Leak : <b>&lt; 3.5</b>      | Result<br><b>PASS</b> |
| Asset ID<br><b>1111</b> | Description :<br>Visual : <b>PASS</b> | Generator power lead | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>415B</b><br>Sub Leak : <b>&lt; 3.5</b>      | Result<br><b>PASS</b> |
| Asset ID<br><b>1112</b> | Description :<br>Visual : <b>PASS</b> | Distribution box     | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1113</b> | Description :<br>Visual : <b>PASS</b> | Distribution box     | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |
| Asset ID<br><b>1114</b> | Description :<br>Visual : <b>PASS</b> | Distribution box     | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b>   | Result<br><b>PASS</b> |

# Detailed Test Report

JobID : **1221542** Company : **KING OF THE CASTLES**  
Engineer : **David Lawton**

Test Date : **14/07/26**  
Total Tests : **70**

|                         |                                                        |                          |                            |                                                          |                       |
|-------------------------|--------------------------------------------------------|--------------------------|----------------------------|----------------------------------------------------------|-----------------------|
| Asset ID<br><b>1115</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1116</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1117</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1118</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1119</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1120</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1121</b> | Description : <b>Splitter</b><br>Visual : <b>PASS</b>  | Earth Cont. : <b>N/A</b> | Insulation : <b>&gt; 2</b> | Test Type : <b>Class 2</b><br>Sub Leak : <b>&lt; 3.5</b> | Result<br><b>PASS</b> |
| Asset ID<br><b>1122</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1123</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1124</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Asset ID<br><b>1125</b> | Description : <b>Extension</b><br>Visual : <b>PASS</b> | Earth Cont. : <b>0.4</b> | Insulation : <b>1.1</b>    | Test Type : <b>EXTLEAD</b><br>Sub Leak : <b>0</b>        | Result<br><b>PASS</b> |
| Room Tests :            |                                                        |                          |                            |                                                          | <b>70</b>             |
| Location Tests :        |                                                        |                          |                            |                                                          | <b>70</b>             |